

Product Name :
Lift Simulator

Product Code :
CE391



Description :

Lift Simulator

Technical Specification :

Lift Simulator
Specifications

The power supply is 24Vdc, the current 1A. The magneto-thermal protections are circuit devices inside the module. It is composed of a cabin M that performs the function of uphill and downhill on the floors.

The position of the cabin, during uphill and downhill, is detected by 5 NO limit switches (micro switch: M 0, M1, M2, MD, MU). The first three (M0, M1, M2) detect the floors according to the following order: M0 for the il ground floor, M1 for the first floor, M2 for the second floor. The remaining two limit switches (MD - MU) are, respectively, the first one for the safety of the overrun downward and the second one for the safety of the overrun upward.

The panel of the module consists of:

3 NO pushbuttons for calling to the floor, named P0, P1 and P2 (P0 ground floor, P1 first floor and P 2 second floor).

3 green LED (floor presence): F0, F1 and F2 (F0 ground floor, F1 first floor and F2 second floor).

In the "lift cabin" section, we have the NO pushbuttons named: C0, C1 and C2, which replicate the function of the pushbuttons named P0, P1 and P2. In the same section, we also have the green LED, named: F0, F1 and F2, and the red LED, named: up, down and DO.

Naugralabequipments

Website: www.naugralabequipments.com, **Email:** sales@naugralabequipments.com

Address: 6148/6, Guru Nanak Marg, Ambala Cantt, Haryana, India. **Phone:** +91-9896600003